

Operator Interface for up to 6 feeders with Congrav[®] CB-E, CM-E and CB-S Control Module

General Information

The Congrav[®] OP6-E is an operating interface that is connected to a [Congrav[®] CB-E](#), [Congrav[®] CB-S](#) or [Congrav[®] CM-E](#) controller via a serial bus link. It provides the basic functions that are required for the operation of multiple Brabender Technologie gravimetric feeders.

The [Congrav[®] OP6-E](#) features a 5.7" colour touch screen which can be used to configure, control and set parameters. The versatile OP6-E can operate the feeders or be used to monitor/set process variables and access diagnostics.

The Congrav[®] OP6-E is compatible with all Brabender Technologie devices equipped with a Congrav[®] CB-E, CB-S or CM-E control module.

The unit conforms to CE directives and exceeds all electromagnetic immunity standards.



Interfaces

Interface to Congrav [®] CM-E, CB-E or CB-S (RS 485)	max. cable length 300 m
Host-/SPS-Interface	Communicate to host systems. Optional Ethernet Modbus TCP or Profibus DP

Technical Specification

Technical Specification	
Rated voltage	DC 24V (20 - 36V) by via the control module CB-E or CM-E. No separate power supply required.
Residual ripple, spikes	< 200mVss; < 300mVss
Rated output	Typ. 12 VA
Rated current	500 mA
Ambient temperature	0°C to +50°C (32°F to +122°F)
Humidity of the air	Up to 85% without condensation
Touch-screen LCD colour display	5.7" / 144 x 105 mm with LED backlight
Resolution	320 x 240 (QVGA)
Housing material	Stainless steel
Front framing	Aluminium
Mounting depth	100 mm (3.9 in) with angled plug connections
Panel cutout	160 x 135 mm (6.2 x 5.3 in)
Weight	Ca. 0.8 kg (1.7 lb)
Enclosure rating – Display only	IP65 (panel mount)
Enclosure rating	IP20
Type of menu	Symbol-based menu with virtual keys

Electromagnetic compatibility (EMC)

Requirement	Standard
ESD	EN 61000-4-2 (2001)
HF radiation	EN 61000-4-3 (2006+A1)
Burst	EN 61000-4-4 (2005)
Surge	EN 61000-4-5 (2007)
Inflow	EN 61000-4-6 (2007)
Interference voltage	CISPR 16 / EN 55011 Class A